



April 29, 2011

Joseph Burke, P.E.
Watts Regulator
815 Chestnut Street
Andover, MA 01845

Dear Mr. Burke:

NSF has reviewed the submission identified below. Based on the product literature, product specifications, metal certification statements and product drawings submitted, the product(s) covered contain a weighted average lead content of less than or equal to 0.25%.

LF1170M2-UT	LFLM490-1	LF1170M2-UT	LFLM490-01	LF1170M2-US
LFLM490-01	LFL1170M2-US	LFLM490-102	LF1170M2-CPVC	LFLM490-3
LF1170M2-PEX	LFM490-4	LFL1170M2-PEX	LFLM490-104	LF1170M2-QC
LFLM490-5	LFL1170M2-QC	LFLM490-105	LFMMVM1-UT	LFLM495-1
LFMMVM1-US	LFLM495-2	LFMMVM1-CPVC	LFLM495-3	LFMMVM1-PEX
LFLM495-4	LFMMVM1-QC	LFLM495-5	LFMMVM1-UT	LFLM496-1
LFLM496-2	LFLM496-3	LFLM496-4	LFLM496-5	LFLM497-1
LFLM497-2	LFLM497-3	LFLM497-4	LFLM497-5	

The weighted average lead content has been calculated using the following formula: The percentage of lead content within each component that comes in contact with water was multiplied by the percent of the total wetted surface of the entire product represented in each component containing lead. These percentages were added and the sum constitutes the weighted average lead content of the product.

These products also meet the requirements of NSF Low Lead Certification Program. For a listing of NSF Certified products, visit www.nsf.org. This letter remains active for one (1) year

Sincerely,

Nancy M. Cistulli
Certification Project Manager
Plastic Piping System Components

email: ncistulli@nsf.org
Phone: 734-827-5673
Fax: 734-827-7895