



April 29, 2011

Dan Barbin
Watts Regulator
815 Chestnut Street
Andover, MA 01845

Dear Mr. Barbin:

NSF has reviewed the submission identified below. Based on the product literature, product specifications, metal certification statements and product drawings submitted, the product(s) covered contain a weighted average lead content of less than or equal to 0.25%.

- 105 Thermostatic Faucet
- 105-6 Thermostatic Faucet
- 105A15 Thermostatic Faucet
- 105A5 Thermostatic Faucet
- 105PW Thermostatic Faucet
- 115 Thermostatic Faucet
- 115-6 Thermostatic Faucet
- 115A15 Thermostatic Faucet
- 115A5 Thermostatic Faucet
- 115PW Thermostatic Faucet
- 205 Thermostatic Faucet
- 205A5 Thermostatic Faucet
- 205PW Thermostatic Faucet
- 215 Thermostatic Faucet
- 215A5 Thermostatic Faucet
- 215PW Thermostatic Faucet
- 0215-6 Thermostatic Faucet

Suffixes:

Suffixes:

- 6 - 6" Handle (4" is the default size)
- A15 - Aerator flow rate is 1.5 gpm
- A5 - Aerator flow rate is 0.5 gpm (default flow rate is 2.0 GPM)
- GD - Grid Drain
- OGD - Offset Grid Drain
- L - Laminar flow outlet
- L5 - 0.5 gpm laminar flow outlet
- PW - Faucet has pop-up waste stopper
- VA - Vandal-resistant aerator
- V5 - Vandal-resistant 0.5 gpm aerator
- VL - Vandal-resistant laminar flow outlet
- VL5 - Vandal-resistant 0.5 gpm laminar flow outlet

Prefixes:

- G - Gooseneck spout
- P - Deck plate



The weighted average lead content has been calculated using the following formula: The percentage of lead content within each component that comes in contact with water was multiplied by the percent of the total wetted surface of the entire product represented in each component containing lead. These percentages were added and the sum constitutes the weighted average lead content of the product.

These products also meet the requirements of NSF Standard 61 Health Effects Annex G. For a listing of NSF Certified products, visit www.nsf.org. This letter remains active for one (1) year

Sincerely,

A handwritten signature in black ink, appearing to read "Nancy M. Cistulli".

Nancy M. Cistulli
Certification Project Manager
Plastic Piping System Components

email: ncistulli@nsf.org
Phone: 734-827-5673
Fax: 734-827-7895